



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Durand Academy
230 North Evergreen Avenue
Woodbury, NJ 08096

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U117413	Field Reagent Blank	03/28/2022 07:00	03/31/2022 13:37	<2.00	15.5	SM3113B
U117414	Gym	03/28/2022 07:05	03/31/2022 13:44	<2.00	15.5	SM3113B
U117415	1st Floor BR	03/28/2022 07:08	03/31/2022 13:50	<2.00	15.5	SM3113B
U117416	2nd Floor Girl	03/28/2022 07:16	03/31/2022 13:56	<2.00	15.5	SM3113B
U117417	Nurce	03/28/2022 07:10	03/31/2022 14:16	2.21	15.5	SM3113B
U117418	Rm 202	03/28/2022 07:12	03/31/2022 14:23	<2.00	15.5	SM3113B
U117419	Rm 205	03/28/2022 07:15	03/31/2022 14:29	<2.00	15.5	SM3113B
U117420	2nd Floor Mens	03/28/2022 07:17	03/31/2022 14:36	<2.00	15.5	SM3113B
U117421	3rd Floor Mens	03/28/2022 07:22	03/31/2022 14:42	<2.00	15.5	SM3113B
U117422	3rd Floor Girls	03/28/2022 07:20	03/31/2022 14:49	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

05/18/2022

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006



Customer: Durand Academy
 Contact: Joe DiBartolo
 Address: 230 North Evergreen Avenue
 Woodbury, NJ 08096
 Phone: _____
 Office: 856-845-0666 x 117

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
1117413	Field Reagent Blank	3/25/22	07:00	D	1 x 250	HNO3*	First Draw Lead	
1117414	GM	3/28/22	07:05	D	1 x 250	HNO3*	First Draw Lead	
1117415	1st HC BR	3/28/22	07:08	D	1 x 250	HNO3*	First Draw Lead	
1117416	2nd HC BR	3/28/22	07:16	D	1 x 250	HNO3*	First Draw Lead	
1117417	Nurse	3/28/22	07:10	D	1 x 250	HNO3*	First Draw Lead	
1117418	Rx 202	3/28/22	07:12	D	1 x 250	HNO3*	First Draw Lead	
1117419	Rx 205	3/28/22	07:15	D	1 x 250	HNO3*	First Draw Lead	
1117420	2nd HW H2O2	3/28/22	07:17	D	1 x 250	HNO3*	First Draw Lead	
1117421	3rd HW H2O2	3/28/22	07:22	D	1 x 250	HNO3*	First Draw Lead	
1117422	3rd HW H2O2	3/28/22	07:20	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GROUND WATER SWSURFACE WATER WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
Standard	NJ DEP Reduced Deliverables		°C
_____	NJ DEP Full Deliverables	* HNO3 preserved upon receipt at laboratory	Properly Preserved
_____	Electronic Data Deliverables		Yes
_____	PWTA Format		No

Sampled by: *Joseph DiBartolo*

Sampled by/Relinquished by: *Joseph DiBartolo*

Relinquished by: _____

Relinquished by: _____

Relinquished by: _____

Received by: <i>Joseph DiBartolo</i>	Date: 3/28/22	Time: 10:32
Received by: _____	Date: _____	Time: _____
Received by: _____	Date: _____	Time: _____